



中国国家强制性产品认证证书

证书编号: 2015010307787691

委托人名称、地址

台安科技(无锡)有限公司
江苏省无锡国家高新技术产业开发区65-C号地块

生产者(制造商)名称、地址

台安科技(无锡)有限公司
江苏省无锡国家高新技术产业开发区65-C号地块

生产企业名称、地址

台安科技(无锡)有限公司
江苏省无锡国家高新技术产业开发区65-C号地块

产品名称和系列、规格、型号

剩余电流动作断路器

TLB-250H1, TLB-250H3;
Ui: 690V; Ue: AC400V; In: 125A, 140A, 150A, 160A, 175A, 180A, 200A, 225A, 250A; 过电流脱扣器类型: 热磁式; Ics: TLB-250H1: 35kA; TLB-250H3: 50kA; Icu: TLB-250H1: 50kA; TLB-250H3: 85kA; IΔn: 0.03/0.1/0.3/0.5A/AC型(I型, 非延时); 0.1/0.3/0.5A/AC型(II型, 非延时、延时可调); 1/3/10A/AC型(III型, 非延时、延时可调); 额定剩余动作类型: AC型(延时型, 非延时型); 剩余电流脱扣器类型: 电子式; IΔm: 25%Icu; 使用类别: A类; 极数: 3P, 4P(3个保护极, N极可开闭);

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2015年07月21日

有效期至: 2020年07月21日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1186928



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2015010307787691

NAME AND ADDRESS OF THE APPLICANT

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME AND ADDRESS OF THE FACTORY

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit Breaker

TLB-250H1, TLB-250H3;
Ui:690V;Ue:AC400V;In:125A, 140A, 150A, 160A, 175A, 180A, 200A, 225A, 250A;Over-
current Trip Unit:Thermal-magnetic;Ics:TLB-250H1:35kA;TLB-
250H3:50kA;Icu:TLB-250H1:50kA;TLB-250H3:85kA;IΔn:0.03/0.1/0.3/0.5A/Type AC
(Type I, Non-delay Type);0.1/0.3/0.5A/Type AC(Type II, Delay Type,
Adjustable delay);1/3/10A/Type AC(Type III, Delay Type, Adjustable
delay);Rated residual action type:Type AC(Delay Type, Non-delay
Type);Residual Current Trip Unit:Electronic;IΔm:25%Icu;Utilization
Category:A;Poles:3P, 4P(Three protected poles with a switched neutral
pole);

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification(REF
NO. CNCA-C03-02:2014).

Date of issue: Jul.21, 2015 Date of expiry: Jul.21, 2020

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

