



# 中国国家强制性产品认证证书

证书编号: 2016010307861478

## 委托人名称、地址

台安科技(无锡)有限公司  
无锡国家高新技术产业开发区65-C号地块

## 生产者(制造商)名称、地址

台安科技(无锡)有限公司  
无锡国家高新技术产业开发区65-C号地块

## 生产企业名称、地址

台安科技(无锡)有限公司  
无锡国家高新技术产业开发区65-C号地块

## 产品名称和系列、规格、型号

### 剩余电流动作断路器

TLB-400H1, TLB-400H3;  
Uimp:8kV;Ui:690V;Ue:AC400V;In:250A, 300A, 315A, 350A, 400A;过电流脱扣器类型:热磁式;Ics:TLB-400H1:35kA;TLB-400H3:50kA;Icu:TLB-400H1:50kA;TLB-400H3:85kA;IΔn:0.03/0.1/0.3/0.5A/AC型(I型, 非延时);0.1/0.3/0.5A/AC型(II型, 非延时, 延时可调);1/3/10A/AC型(III型, 非延时, 延时可调);额定剩余动作类型:AC型(延时型, 非延时型);剩余电流脱扣器类型:电子式;IΔm:25%Icu;使用类别:A类;极数:3P, 4P(3个保护极, N极可开闭)

## 产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则  
CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2016年05月05日

有效期至: 2021年05月05日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1390152



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2016010307861478

## NAME AND ADDRESS OF THE APPLICANT

TAIAN Technology (Wuxi) Co., Ltd.  
Block 65-C, Wuxi National High-Technology Industry Development  
Zone, Wuxi, Jiangsu Province, P. R. China

## NAME AND ADDRESS OF THE MANUFACTURER

TAIAN Technology (Wuxi) Co., Ltd.  
Block 65-C, Wuxi National High-Technology Industry Development  
Zone, Wuxi, Jiangsu Province, P. R. China

## NAME AND ADDRESS OF THE FACTORY

TAIAN Technology (Wuxi) Co., Ltd.  
Block 65-C, Wuxi National High-Technology Industry Development  
Zone, Wuxi, Jiangsu Province, P. R. China

## NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit Breaker

TLB-400H1, TLB-400H3;  
Uimp:8kV;Ui:690V;Ue:AC400V;In:250A, 300A, 315A, 350A, 400A;Over-current Trip  
Unit:Thermal-magnetic;Ics:TLB-400H1:35kA;TLB-400H3:50kA;Icu:TLB-  
400H1:50kA;TLB-400H3:85kA;IΔn:0.03/0.1/0.3/0.5A/Type AC(Type I, Non-delay  
Type);0.1/0.3/0.5A/Type AC(Type II, Delay Type, Adjustable  
delay);1/3/10A/Type AC(Type III, Delay Type, Adjustable delay);Rated  
residual action type:Type AC(Delay Type, Non-delay Type);Residual Current  
Trip Unit:Electronic;IΔm:25%Icu;Utilization Category:A;Poles:3P, 4P(Three  
protected poles with a switched neutral pole)

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the  
requirements of implementation rules for compulsory certification(REF  
NO. CNCA-C03-02:2014).

Date of issue: May. 05, 2016      Date of expiry: May. 05, 2021

Validity of this certificate is subject to positive result of the regular  
follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

