



中国国家强制性产品认证证书

证书编号: 2006010307200848

委托人名称、地址

台安科技(无锡)有限公司
无锡国家高新技术产业开发区65-C号地块

生产者(制造商)名称、地址

台安科技(无锡)有限公司
无锡国家高新技术产业开发区65-C号地块

生产企业名称、地址

台安科技(无锡)有限公司
无锡国家高新技术产业开发区65-C号地块

产品名称和系列、规格、型号

剩余电流动作断路器

BOL-250S

Ue: AC400V; In: 100, 125, 140, 160, 180, 200, 225, 250A; I Δ n: 0.03, 0.1, 0.3, 0.5A/AC型
(I型, 非延时); 0.1, 0.3, 0.5A/AC型(II型, 非延时, 延时可调); 1, 3, 10A/AC型(III型, 非
延时, 延时可调); 使用类别: A类; I Δ m: 12.5kA; 剩余电流脱扣器类型: 电子
式; Icu: 50kA; Ics: 42kA; 极数: 3P, 4P

产品标准和技术要求

GB 14048.2-2008

上述产品符合强制性产品认证实施规则
CNCA-C03-02: 2014的要求, 特发此证。

发证日期: 2014年12月23日

有效期至: 2019年12月23日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2006年09月15日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 1064515



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2006010307200848

NAME AND ADDRESS OF THE APPLICANT

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME AND ADDRESS OF THE MANUFACTURER

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME AND ADDRESS OF THE FACTORY

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P. R. China

NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit Breaker

BOL-250S

Ue: AC400V; In: 100, 125, 140, 160, 180, 200, 225, 250A; $I\Delta n$: 0.03, 0.1, 0.3, 0.5A/Type
AC (Type I, non-time-delay); 0.1, 0.3, 0.5A/Type AC (Type II, non-time-
delay, adjustable time-delay); 1, 3, 10A/Type AC; (Type III, non-time-
delay, adjustable time-delay); Utilization Category: A; $I\Delta m$: 12.5kA; Electronic
Residual Current Tripping Unit; Icu: 50kA; Ics: 42kA; Poles: 3P, 4P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the
requirements of implementation rules for compulsory certification (REF
NO. CNCA-C03-02:2014).

Date of issue: Dec. 23, 2014 Date of expiry: Dec. 23, 2019

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.

Date of original certification: Sep. 15, 2006

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

<http://www.cqc.com.cn>



Q 1064515